

Addendum – 1

Project:  
Virginia Credit Union  
202 N Main St  
Blacksburg, VA

The following addendum supplements and amends the bid documents and shall be considered in preparing proposals on the subject project. Receipt of this Addendum must be noted within the bid form.

RESON FOR ADDENDUM: Owner Requested Updates Revision 1

Drawings included with this addendum: G1.1 G1.2, A1.1, A2.1, A5.1, A8.1, EQ.1, AS.4, AS.5, AS.6, AS.7 P1.1, H1.0, E1.1, E2.1, and E3.1

Item 1: Sheet G1.1 – Index Sheet & General Information

- A. Sheet Index: Added new sheet AS.7 to index
- B. Sheet Index: Added new sheet A2.1 to index

Item 2: sheet G1.2 – Life safety Plan

- A. Life Safety Plan:
  - 1. Renamed “Storage Room 122” to “Electrical Room 122”
  - 2. Relocated the electrical panels from “IT/Electrical Room 121” to Electrical Room 122”
  - 3. Flipped the door swing of door D – 122 and adjusted its position
  - 4. Flipped the door swing of door D – 121 and adjusted its position
  - 5. Waiting 102: Updated emergency light quantities and locations.
  - 6. Teller 112: Updated emergency light quantities and locations
  - 7. Stair 115: Updated emergency light quantities and locations
  - 8. Breakroom 116: Updated emergency light quantities and locations
  - 9. Corridor 118: Updated emergency light quantities and locations.
  - 10. Stair 120: Updated emergency light quantities and locations.
  - 11. IT/Elec 121: Updated emergency light quantities and locations.
  - 12. Elec Room 122: Updated emergency light quantities and locations.
  - 13. Corridor 128: Updated emergency light quantities and locations.
  - 14. Unoccupied 129: Updated emergency light quantities and locations.

Item 3: Sheet A1.1 – Floor plan and details

- A. Floor Plan:
  - 1. Renamed “Storage Room 122” to “Electrical Room 122”
  - 2. Relocated the electrical panels from IT/Electrical Room 121” to “Electrical Room 122”
  - 3. Flipped the door swing of door D – 122 and adjusted its position
  - 4. Flipped the door swing of door D – 121 and adjusted its position



- A. Electrical Room 1222
  - 1. Added plywood to walls indicated.

**Item 4" Sheet A5.1 – Floor Finish Plan and Details**

- A. Floor finish plan
  - 1. Renamed "Storage Room 122" to Electrical Room "122"
  - 2. Relocated the electrical panels from "IT/Electrical Room 121" to Electrical Room 122"
  - 3. Flipped the door swing of door D-122 and adjusted its position
  - 4. Adjusted start tile to be centered on new door location in Room 122
  - 5. Flipped the door swing of door D-121 and adjusted its position

**Item 5: Sheet A8.1 – Reflected Ceiling Plan**

- A. Reflected ceiling plan
  - 1. Renamed "Storage Room 122" to "Electrical Room 122"
  - 2. Adjusted door head location of doors D-122 & D-121

**Items 6" Sheet EQ.1 – Equipment Plan**

- A. Equipment Plan
  - 1. Renamed "Storage Room 122" to "Electrical Room 122"
  - 2. Relocated the electrical panels from "IT/Electrical Room 121" to "Electrical Room 122"
  - 3. Flipped the door swing of door D-122 and adjusted its position
  - 4. Flipped the door swing of door D-121 and adjusted its position

**Item 7: Sheet AS.4 – Architectural Specifications**

- A. Division 8- Openings: Updated Door Hardware (08 71 00) information

**Item 8: Sheet AS.5 – Architectural Specifications**

- A. Division 8- Openings: Updated Door Hardware (08 71 00) information

**Item 9: Sheet AS.6 Architectural Specifications**

- A. Sheet Replaced due to updated Door Hardware specification

**Item 10: Sheet AS.7 – Architectural Specifications**

- A. Sheet added due to updated Door Hardware specification.

**Item 11: Sheet P1.1 – Plumbing Plan**

- A. Floor Plan
  - 1. Added "STAIR 120" room tag to plans.
  - 2. Updated "Storage Room 122" to be named "ELEC. RM 122"

**Item 12: Sheet H.10 – HVAC Plan**

- A. Floor Plan
  - 1. Added "STAIR 120" room tag to plans.
  - 2. Updated "Storage Room 122" to be named "ELEC/ RM 122"



Item 13: Sheet E1.1 – Electrical Lighting Plan

A. Floor Plan:

1. Relocated the electrical panels, timeclock and contactors from “IT/ELEC. 121” to ELEC. RM 122”
2. Updated lighting fixture in “ELEC. ROOM 122” furthest from doorway to be emergency.
3. Revised EM fixtures nearest to doorways to be non-EM.
4. Flipped the door swing of door D-122 adjusted its position.
5. Updated “Storage Room 122” to be named “ELEC RM 122”
6. Revised toilet room names to coordinate with architecture specifying men’s and women’s
7. Revised IT/Elec Room 121 door to swing outward.

Item 14: Sheet E2.1 – Electrical Power Plan

A. Floor Plan

1. Relocated the electrical panels, and metering devices from “IT/ELEC. 121” to “ELEC. RM 122”
2. Revised floor D-1222 to swing outward and adjusted its position.
3. Revised IT/Elec room 121 door to swing outward.
4. Updated “Storage Room 122” to be named: ELEC RM 122”
5. Added “STAIR 120” room tag to plans
6. Revised toilet room names to coordinate with architecture specifying men’s and women’s
7. Added receptacle for panels and circuited to panel B-46.

Item 15: Sheet E3.1 – Electrical Power Riser Diagram

A. Panel Schedules

1. Added panel receptable to circuit B-46
2. Added the description ‘Spare’ circuits B-43-54 for clarification.

Item 16: Sheet A2.1 – Drive Up Canopy

A. Canopy and drive through lane

1. The addition of a standalone drive-up canopy and drive through lane.

End of Addendum 1

